## COMMONWEALTH OF KENTUCKY

## BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF MARION COUNTY WATER )
DISTRICT FOR A DEVIATION FROM THE ) CASE NO. 94-525
REQUIREMENTS FOR WATER STORAGE )

## ORDER

By application received December 21, 1994, Marion County Water District ("Marion Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 4(4), which requires that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Marion Water states in its application that its average daily water usage, including unaccounted-for water, is approximately 900,000 gallons, and that its current water storage capacity is 510,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

- 1. Marion Water is not in compliance with Commission Regulation 807 KAR 5:066, Section 4(4).
- 2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Marion Water should be given until January 1, 2000 to comply with 807 KAR 5:066, Section 4(4).

## IT IS THEREFORE ORDERED that:

Marion Water be and it hereby is given until January 1,
 2000 to comply with the provisions of 807 KAR 5:066, Section 4(4).

2. Marion Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2000.

Done at Frankfort, Kentucky, this 17th day of January, 1995.

PUBLIC SERVICE COMMISSION

halrman

Vice Chairman

Commissioner Do

ATTEST:

Executive Director